

# Understanding your recent fire risk assessment

---



Scheme name:

Brownberrie Walk No 56-61

Date of Fire Risk Assessment: 07/06/19

The current evacuation policy for your scheme is:  
**Stay put (delayed evacuation)**

---

## Who We Are

---

Pennington Choices provides property surveying and consultancy services to organisations nationwide.

We provide fire risk assessments on behalf of your housing provider, Leeds and Yorkshire Housing Association (LYHA). Fire risk assessments are a legal requirement and are therefore a standard procedure and not a cause for concern. They also help your housing provider to identify what they need to do to further prevent fires and keep you safe.

On the 7<sup>th</sup> June 2019 our assessor carried out a fire risk assessment at your scheme. The assessment was taken to identify and prevent any possible fire risks. These assessments will help LYHA to keep you safe and up to date on what to do if you do have a fire.

Should you have any queries then please contact:

Norman Davidson  
Assurance and Compliance Manager  
Leeds and Yorkshire Housing Association  
Email: [norman.davidson@lyha.co.uk](mailto:norman.davidson@lyha.co.uk)  
Tel: 0113 220 8103

\*This report is intended for residents only

---

# Why does my scheme need a fire risk assessment?

---

All schemes that have communal areas, such as corridors and common rooms, are required under legislation to have a fire risk assessment completed.

These fire risk assessments should be reviewed regularly or if your scheme's communal area has had any changes made to it, for example, extensions and changes to the building layout.

The risk assessment will identify fire risks that may be present within your scheme / property and make recommendations for improvement, if needed.

The type of things the assessors will review are:

- Fire alarm and detection
- Emergency lighting
- Fire doors
- Compartmentation
- Firefighting equipment
- Escape strategies
- Signage (in communal areas)

Please note, not all of these things will be necessary in your scheme.

The risk assessor will establish a time period for when another risk assessment should be taken for your property based on the potential risks. This means you may not have had a fire risk assessment for up to three years previously or may not need another one for the next three years after this one. However, rest assured that the fire risk assessment is reviewed regularly during this period or when any major change takes place on your scheme.

---

# Fire Risk Assessment and action plan

---

A fire risk assessment is a lengthy and technical document, normally in excess of 30 pages. However, the most important part of the risk assessment is the action plan, which you will find a copy of below.

An action plan is created when your risk assessment is completed. The assessor will take an opinion of the risks at the time of the visit and make recommendations to make your scheme safer.

As you will see in the plan below, the risks range from high and medium to low. Alongside the noted risks are recommended dates for the risks to be addressed. Please note these dates are a rough guideline based on the opinion of the risk assessor.

LYHA have a remedial maintenance programme in place to achieve completion of your action plan therefore for practical reasons some actions may not necessarily be completed within the suggested dates below.

Any immediate risks (high priority) are flagged to LYHA immediately at the time of the inspection and therefore will be addressed as soon as possible.

If you would still like to view the whole risk assessment, you can request a copy from LYHA.



The table below show your scheme's action plan; the risks identified and suggestions as to how LYHA can fix them in line with current regulations:

Question	Risk Rating	Observations	Recommendations	Target Date
Are the premises secured against Arson?	Low	There is unrestricted access to the internal common areas of the block.	Consider providing a secure door access control system.	13/12/2019
Is the standard of housekeeping adequate, taking into consideration combustibles within close proximity of ignition sources, accumulation of combustible materials or waste within the premises or stored within escape routes/auxiliary rooms etc.?	Medium	Combustible items are present in the common area at second floor level.	Remove the combustible items and remind the residents of the safe corridors policy. Signage displayed in the common areas (present in some other premises) would be beneficial to reinforce the policy.	13/09/2019
If there is any glazing in any off the doors or frames can it be identified as suitable?	Medium	No identification markings could be found that would indicate that the glazing within all flat entrance doors and the fanlights above was fire resisting. The acid etching present on the common area facing side stated 'laminated glass EN14449'.	Investigate the fire resistance properties of the door glazing and the fanlights above. It is possible that as the doors and fanlights are double glazed, and the inner flat facing glazing is fire resistant. The contractor who fitted the doors may also be able to help. If it is found that none of the glazing is fire resistant, then arrangements should be made for its replacement.	13/09/2019

<p>Does the provision of signage comply with the Health and Safety (Safety Signs and Signals) Regulations 1996, taking into consideration fire exit signs, directional arrow signs, fire door condition signs, fire action notices, firefighting equipment ID and Lift signs etc. (including “No Smoking” signs)</p>	<p><b>Medium</b></p>	<p>A no smoking sign should be displayed in the common area, close to the block entrance door.</p>	<p>Display a no smoking sign in the common area, close to the block entrance door.</p>	<p>13/09/2019</p>
--	----------------------	--	--	-------------------

# General fire safety information

Many people worry about fires in the home, but with care and the correct measures, it can be prevented. LYHA do their part to keep you safe, but there are basic things you can follow to make sure your home is safe:

