

Elmete Way Caretaker store (69-121 Elmete Way), Leeds, LS8 2ND

Area	Action	Frequency	By	Location
POU Water Heaters (15 Litres max)	Check water temperatures (should be 50 – 60°C, 55°C in healthcare premises within one minute)	Monthly	Elmetes Caretaker	Caretaker store 69-121 Elmete Way
Cold Water Services	Check temperatures at sentinel taps	Monthly	Elmetes Caretaker	Caretaker store 69-121 Elmete Way
	Check temperatures at a representative selection of other points(Should be below 20°C)	Monthly	Elmetes Caretaker	Caretaker store 69-121 Elmete Way
POU Filters	Record the service start date and lifespan, or end date and replace filters as recommended by	TBC	Elmetes Caretaker	Caretaker store 69-121 Elmete Way
Infrequently used outlets	Flush little used outlets until the water temperature stabilises and is comparable to the supply water	Minimum Weekly	Elmetes Caretaker	Caretaker store 69-121 Elmete Way

Note:

Frequency may need to be increased if outlets are seen to become heavily scaled between cleaning actions.