

Area	Action	Frequency	By	Location
Cold Water Services	Check temperatures at sentinel taps	Monthly	Block Inspector	Laundry room
	Check temperatures at a representative selection of other points (Should be below 20°C)	Monthly	Block Inspector	Laundry room
	Descale any heavily scaled taps	Annually	Block inspector	Laundry room
Infrequently used outlets	Flush little used outlets until the water temperature stabilises and is comparable to the supply water	Minimum Weekly	Block Inspector	Laundry room

Note:

Frequency may need to be increased if outlets are seen to become heavily scaled between cleaning actions.