

Control Scheme St Mary's Court Caretakers store

Area	Action	Frequency	By	Location
POU Water Heaters (15 Litres max)	Check water temperatures (should be 50 – 60°C, 55°C in healthcare premises within one minute)	Monthly	The responsible person or a nominated	Caretaker store
Cold water services	Check temperatures at a representative selection of other points (Should be below 20°C)	Monthly	The responsible person or a nominated	Caretaker store
Infrequently used outlets	Flush little used outlets until the water temperature stabilises and is comparable to the supply water	Minimum Weekly	The responsible person or a nominated	Caretaker store

Note:

Frequency may need to be increased if outlets are seen to become heavily scaled between cleaning actions.